

GSTIN No. : 05BZ8PK0835Q1Z6

**Sidhbali**  
Enterprises

Ref. Refill / HTP -24

Date: - 10-05-24

**Fire (H.P.T.) Certificate**

NAME of Firm / Party:-	UNICUS ACADEMY (Shivnanda Education Society)
ADDRESS:-	Laxampur, Kotdwar, Pauri Garhwal Uttarkhand
HYDRO TEST PRESSURE	ABC/AB=35Kgf/cm <sub>2</sub>
CHEMICAL Refilled	Mono ammonium phosphate in ABC
Refilled Numbers of Extinguisher	ABC 4kg = 12 Nos. and Foam 9Ltr=01 Nos
Date of Testing on	10-05-24
Next due date of testing on	09-05-25

Warranty: - The above mentioned equipments are warranted against its refilling & gas charged under normal use. The warranty is limited to a period of one year from the date of refilling. The company's obligation shall be limited to rectifying, repairing or replace defective parts. No claim shall be valid if physical damage.

For:-

Sidhbali Enterprises

शिवानन्द एजुकेशनल सोसायटी

PRESIDENT / SECRETARY  
SHIVNANDA EDUCATIONAL SOCIETY  
VILL & P.O.- SHIVRAJPUR  
KOTDWARA GARHWAL (U.K.) 246140

Kotdwar ( Pauri Garhwal) Uttarakhand  
E-mail : sidhbali.fire@gmail.com

9837187883  
7983225964